

Results from the March 10, 2023 sampling were received today and show continued improvement in the HAA5 levels. These tests were conducted at Town locations as well as several private residences. The levels leaving the East Rd. Pump Station (33.7) are below the MCL and the levels in the tank (47.5) are now below the MCL. Testing levels at the private residences ranged from 42.2 to 46.4, all below the MCL.

Below are two graphs that show the levels to date for testing performed at Town sites.

Flushing and sampling will continue to ensure the water quality is continuously improving.

