



STATE OF NEW HAMPSHIRE DEPARTMENT OF SAFETY

John J. Barthelmes, Commissioner

Division of Fire Safety
Office of the State Fire Marshal

J. William Degnan, State Fire Marshal

Office: 110 Smokey Bear Blvd., Concord, NH

Mailing Address: 33 Hazen Drive, Concord, NH 03305

PHONE 603-223-4289, FAX 603-223-4294 or 603-223-4295

TDD Access: Relay NH 1-800-735-2964 ARSON HOTLINE 1-800-400-3526



July 28, 2016

Jame Ortiz
Corporate Counsel for Amazon
440 Terry Ave North
Seattle, WA 98109

Dear Ms. Ortiz,

It was recently brought to our attention that Amazon is selling smoke alarms and carbon monoxide alarms that do not carry the listing labels from nationally recognized third-party testing laboratories such as Underwriter Laboratories (UL) or Intertek/ETL.


The New Hampshire State Fire Marshal's Office has contacted these two laboratories and has found that the *X-Sense, Arikon, and Bovon* devices are not compliant for sale in the State of New Hampshire per *UL 217 – Standard for Smoke Alarms* and *UL 2034 – Standard for Single and Multiple Station Carbon Monoxide Alarms*.

The New Hampshire State Fire Marshal's Office is requesting the cease of sales to the State of New Hampshire immediately, and until such time that these devices become properly test and listed by an approved third-party agency.

Please provide an address list where the device brands listed above have been shipped to in the State of New Hampshire, so that appropriate warning can be made regarding their lack of approved and recognized third-party testing.

Public safety is of the utmost importance to us, and we thank you for your cooperation regarding this matter.

Sincerely,


J. William Degnan
Director/ State Fire Marshal
NH State Fire Marshal's Office