490 East Industrial Park Drive Manchester, NH 03109 www.nelsonanalytical.com (603)622-0200 NH ELAP Accreditation #NH1005

NELSON ANALYTICAL LAB

Maine State Certification #NH01005

Vermont State Cerfication # VT1005

Maine Radon Certification # ME17500

Massachusetts State Certification #M-NH1005

Report of Analysis

Client Name: Lewis Builders
System Name: Plaistow Water Dept

Laboratory ID: 123062496.01

Sample Site ID: 0-

System Town: Plaistow

Sample Location: EAST ROAD SUCTION

Date/Time Collected: 06/23/2023 09:41 AM

PWSID: 1931010

Date/Time Rec'd: 06/23/2023 02:40 PM

Collected By: R. Bibeau Temperature Rec'd °C: #18.8

Comp. Period and Type: Q2 2023 OT GSES

Parameter	Result	Units	Method	Rpt Limit	Reg Limit	Date/Time Analyzed	Analyst
Bromodichloromethane	11.6	ug/L	EPA 524.2	0.5	NA	06/27/2023 20:44	KD
Bromoform	< 0.8	ug/L	EPA 524.2	0.8	NA	06/27/2023 20:44	KD
Chloroform	31.9	ug/L	EPA 524.2	0.5	NA	06/27/2023 20:44	KD
Dibromochloromethane	3.1	ug/L	EPA 524.2	0.8	NA	06/27/2023 20:44	KD
Total Trihalomethanes	46.6	ug/L	EPA 524.2	2.6	80	06/27/2023 20:44	KD
Bromochloroacetic acid	5.1	ug/L	EPA 552.2	1	NA	06/29/2023 12:00	SUB8
Dibromoacetic acid	<1.0	ug/L	EPA 552.2	1	NA	06/29/2023 12:00	SUB8
Dichloroacetic acid	21	ug/L	EPA 552.2	1	NA	06/29/2023 12:00	SUB8
Monobromoacetic acid	<1.0	ug/L	EPA 552.2	1	NA	06/29/2023 12:00	SUB8
Monochloroacetic acid	3.4	ug/L	EPA 552.2	2	NA	06/29/2023 12:00	SUB8
Trichloroacetic acid	17	ug/L	EPA 552.2	1	NA	06/29/2023 12:00	SUB8
Total Haloacetic Acids	46.5	ug/L	EPA 552.2	1	60	06/29/2023 12:00	SUB8

Client Name: Lewis Builders

Laboratory ID: 123062496.02

Plaistow Water Dept

Sample Site ID: 0-

System Name:

System Town: Plaistow

Sample Location: SWEET HILL TANK

Date/Time Collected: 06/23/2023 10:30 AM

PWSID: 1931010

Date/Time Rec'd: 06/23/2023 02:40 PM

Collected By: R. Bibeau Temperature Rec'd °C: #18.8

Comp. Period and Type: Q2 2023 OT GSES

Parameter	Result	Units	Method	Rpt Limit	Reg Limit	Date/Time Analyzed	Analyst
Bromodichloromethane	11.0	ug/L	EPA 524.2	0.5	NA	06/27/2023 21:12	KD
Bromoform	< 0.8	ug/L	EPA 524.2	0.8	NA	06/27/2023 21:12	KD
Chloroform	37.6	ug/L	EPA 524.2	0.5	NA	06/27/2023 21:12	KD
Dibromochloromethane	2.8	ug/L	EPA 524.2	0.8	NA	06/27/2023 21:12	KD
Total Trihalomethanes	51.4	ug/L	EPA 524.2	2.6	80	06/27/2023 21:12	KD
Bromochloroacetic acid	5.0	ug/L	EPA 552.2	1	NA	06/29/2023 12:00	SUB8



Notes: mg/L=ppm; ng/L=ppb; ng/L=ppb;

laboratory on not meet metnod speciment temperature criteria.

Solid samples are reported on a dry weight basis unless noted otherwise.

For accreditation status at the time of sample analysis, or for information on subcontract laboratories, please contact Nelson Analytical.

Subcontract Laboratories: SUB2: Nelson Analytical Maine NH2018 SUB 7: Nelson Analytical EAI Div. NH1007, SUB3: 2062 SUB4:2073/2239, SUB5:NH2530, SUB8:NH2136, https://www4.des.state.nh.us/OneStopPub/WSEB/acclab/1005.pdf

http://healthvermont.gov/enviro/ph_labj/PublicHealthLaboratory.aspx https://www.maine.gov/dhhs/mecdc/environmental-health/dwp/professionals/labCert.shtml https://www.mass.gov/certified-laboratories

Date reported: 07/11/2023 12:14



490 East Industrial Park Drive Manchester, NH 03109 www.nelsonanalytical.com (603)622-0200 NH ELAP Accreditation #NH1005

NELSON ANALYTICAL LAB

Maine State Certification #NH01005 Vermont State Cerfication # VT1005 Maine Radon Certification # ME17500

Massachusetts State Certification #M-NH1005

Report of Analysis

Client Name: Lewis Builders Plaistow Water Dept System Name:

123062496.02 Laboratory ID:

Sample Site ID: 0-

System Town: Plaistow

Sample Location: **SWEET HILL TANK** **Date/Time Collected:** 06/23/2023 10:30 AM

PWSID: 1931010

Date/Time Rec'd: 06/23/2023 02:40 PM

Collected By: R. Bibeau Temperature Rec'd °C: #18.8

Comp. Period and Type: **O2** 2023 OT **GSES**

-							
Parameter	Result	Units	Method	Rpt Limit	Reg Limit	Date/Time Analyzed	Analyst
Dibromoacetic acid	<1.0	ug/L	EPA 552.2	1	NA	06/29/2023 12:00	SUB8
Dichloroacetic acid	24	ug/L	EPA 552.2	1	NA	06/29/2023 12:00	SUB8
Monobromoacetic acid	<1.0	ug/L	EPA 552.2	1	NA	06/29/2023 12:00	SUB8
Monochloroacetic acid	5.3	ug/L	EPA 552.2	2	NA	06/29/2023 12:00	SUB8
Trichloroacetic acid	22	ug/L	EPA 552.2	1	NA	06/29/2023 12:00	SUB8
Total Haloacetic Acids	56.3	ug/L	EPA 552.2	1	60	06/29/2023 12:00	SUB8

Lewis Builders Client Name: System Name: Plaistow Water Dept

123062496.03 Laboratory ID:

Sample Site ID: 0-**System Town: Plaistow**

FREEDOM TIRE Sample Location:

Date/Time Collected: 06/23/2023 09:59 AM **PWSID:**

1931010

Date/Time Rec'd: 06/23/2023 02:40 PM

Collected By: R. Bibeau Temperature Rec'd °C: #18.8

Comp. Period and Type: 2023 OT $\mathbf{Q2}$ **GSES**

Parameter	Result	Units	Method	Rpt Limit	Reg Limit	Date/Time Analyzed	Analyst
Bromodichloromethane	10.1	ug/L	EPA 524.2	0.5	NA	06/27/2023 21:41	KD
Bromoform	< 0.8	ug/L	EPA 524.2	0.8	NA	06/27/2023 21:41	KD
Chloroform	30.3	ug/L	EPA 524.2	0.5	NA	06/27/2023 21:41	KD
Dibromochloromethane	3.1	ug/L	EPA 524.2	0.8	NA	06/27/2023 21:41	KD
Total Trihalomethanes	43.5	ug/L	EPA 524.2	2.6	80	06/27/2023 21:41	KD
Bromochloroacetic acid	4.6	ug/L	EPA 552.2	1	NA	06/29/2023 12:00	SUB8
Dibromoacetic acid	<1.0	ug/L	EPA 552.2	1	NA	06/29/2023 12:00	SUB8
Dichloroacetic acid	19	ug/L	EPA 552.2	1	NA	06/29/2023 12:00	SUB8
Monobromoacetic acid	<1.0	ug/L	EPA 552.2	1	NA	06/29/2023 12:00	SUB8
Monochloroacetic acid	5.2	ug/L	EPA 552.2	2	NA	06/29/2023 12:00	SUB8
Trichloroacetic acid	18	ug/L	EPA 552.2	1	NA	06/29/2023 12:00	SUB8
Total Haloacetic Acids	46.8	ug/L	EPA 552.2	1	60	06/29/2023 12:00	SUB8



Notes: mg/L=ppm; ug/L=ppb; ng/L=ppb; ng/L=ppt, "<" denotes "less than". This report of analysis may not be modified in any way, or reproduced except in full, without written approval from Nelson Analytical, LLC. Results Notes: mg/L=pppr, ug/L=pppr, "c" denotes "less than". In its report of analysis may not be modified in any way, or reproduced except in full, without written approval from Nelson Analytical, LLC. Results reported above relate only to samples as submitted, unless specifically noted otherwise. Nelson Analytical, LLC is currently accredited by the New Hampshire Environmental Lab Accreditation Program, the Vermont Laboratory Accreditation Program, the Massachusetts Laboratory Certification Program, and the Maine Laboratory Accreditation Program. For a list of current accredited tests, please visit the websites listed below. Sampling performed by the lab is according to the lab document "Water Sampling Instructions". EPA standards list pl & Chlorine as field parameters which should be tested immediately upon sample collection. Samples tested for pH after submission are beyond the hold time. Samples will be analyzed as quickly as laboratory operations allow. Metals samples may be analyzed the same day they are received. #-Sample(s) received at laboratory do not meet method specified temperature criteria.

Solid samples are reported on a dry weight basis unless noted otherwise.

For accreditation status at the time of sample analysis, or for information on subcontract laboratories, please contact Nelson Analytical.

Subcontract Laboratories: SUB2: Nelson Analytical Maline MP2018 SUB 7: Nelson Analytical FAI Div. 11007, SUB3: 2062 SUB4:2073/2239, SUB5:NH2530, SUB8:NH2136, https://www.d.des.state.nh.us/OneStopPub/WSEB/acclab/1005.pdf

http://healthvermont.gov/enviro/ph lab/PublicHealthLaboratory.aspx https://www.maine.gov/dhhs/mecdc/environmental-health/dwp/professionals/labCert.shtml https://www.mass.gov/certified-laboratories

Date reported: 07/11/2023 12:14



490 East Industrial Park Drive Manchester, NH 03109 www.nelsonanalytical.com (603)622-0200 NH ELAP Accreditation #NH1005

NELSON ANALYTICAL LAB

Maine State Certification #NH01005 Vermont State Cerfication # VT1005 Maine Radon Certification # ME17500 Massachusetts State Certification #M-NH1005

Report of Analysis

Respectfully Submitted

Kumby Water Kimberly Wright, Quality Assurance Manager

Notes: mg/L=ppp; ug/L=ppp; re/" eleotes "less than". This report of analysis may not be modified in any way, or reproduced except in full, without written approval from Nelson Analytical, LLC. Results reported above relate only to samples as submitted, unless specifically noted otherwise. Nelson Analytical, LLC is currently accredited by the New Hampshire Environmental Lab Accreditation Program, the Massachusetts Laboratory Certification Program, and the Maine Laboratory Accreditation Program. For a list of current accredited tests, please visit the websites listed below. Sampling performed by the lab is according to the lab document "Water Sampling Instructions". EPA Standards list pt H & Chlorine as field parameters which should be tested immediately upon sample collection. Samples tested for pH after submission are beyond the hold time. Samples will be analyzed as quickly as laboratory operations allow. Metals samples may be analyzed the same day they are received. #-Sample(s) received at laboratory do not meet method specified temperature criteria.

Solid samples are reported on a dry weight basis unless noted otherwise.

For accreditation status at the time of sample analysis, or for information on subcontract laboratories, please contact Nelson Analytical.

Subcontract Laboratories: SUB2: Nelson Analytical EAI Div. NH1007, SUB3: 2062 SUB4:2073/2239, SUB5:NH2530, SUB8:NH2136, https://www4.des.state.nh.us/OneStopPub/WSEB/Acclab/1005.pdf

https://www4.des.state.nh.us/OneStopPub/WSEB/Acclab/1005.pdf

https://www.maine.gov/dhhs/mecdc/environmental-health/dwp/professionals/labCert.shtml

https://www.maine.gov/dehfs/mecdc/environmental-health/dwp/professionals/labCert.shtml

Date reported: 07/11/2023 12:14